

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/2024/SZ/School/554

Dated: 20/06/2024

FIRE SAFETY CERTIFICATE

Certified that the building MCD Co. Ed Primary School, located at Manglapuri-1 & II, Palam, New Delhi-110045 comprised of Ground + One Upper Floor owned / occupied by MCD was issued Fire Safety Certificate vide this department letter No. F.6/DFS/MS/2021/SZ/531 dated 26/07/2021. The premises was re inspected by the officer concerned of this department on 10/06/2024 in the presence of Sh. Munmun Kr. Singh (Teacher) and found that premises have deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 3298-3398 Dated 01/03/2011 issued by the Director of Education and that the building is fit for occupancy class B "Educational building" with effect from 20/06/2024 for a period of three years, subject to condition given below.

Issued on 20/06/2024 at New Delhi by.

(Atul Garg)
Director
Delhi Fire Service.

Copy to:

1. The Principal MCD Co. Ed Primary School, located at Manglapuri-1 &II, Palam, New Delhi-110045 (School Id-1757158)
2. Directorate of Education Old Secretariat Delhi – 110054

Following fire safety directives must be adhered to:-

1. **The FSC shall be null & void if pota cabin is used for school activities.**
2. **Pota cabins seen in the school premises shall not be used for school activities.**
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
9. Basement shall be used strictly as per building bye laws.
10. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/21

INSPECTION REPORT

3. Name & address of the building: MCD Co. Ed Primary School, located at Manglapuri-1 &II, Palam, New Delhi-110045(School Id-1757158)
4. Type of Occupancy : Educational (Ground + 01 Upper Floor)
5. Type of Case : Renewal
6. Details of previous NOC : F.6/DFS/MS/2021/SZ/531 dated 26/07/2021
7. Fire Safety directives Letter No. : DOE Circular 3298 -3398 Dated 01/03/2011
8. Date of inspection : 10/06/2024
9. Name of the Inspecting Officer : ADO (DWK)
10. Name and designation of Officer from the building side : Sh. Munmun Kr. Singh (Teacher)
11. Year of Construction : Before 2010
12. Applicant's letter No. : Email dated- 18/05/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Circular dated 1/03/2011 As per N/5	Provided at site	Remarks MR/NMR
1.	Access of building	06 mtrs	10 mtr	MR
	• Road width	4.5mtrs	Directly accessible from road	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	02 No's	02 No's	MR
	• Upper floors	NA	NA	NA
	• Basements			
	b. Width of staircases	1.5 m if less 1.5 mtr additional staircase of 0.75 mtr is required	1.64 & 1.82 mtr	MR (Old case)
	• Upper floors	NA	NA	NA
	• Basements			
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	01 mtr	01 mtr including door frame	MR (Old case)
	f. Door Size			
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA


4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	08ABC & CO ₂	08 Nos.	MR
	• Types	ISI marked	CO ₂ & ABC	MR
	• IS marking		Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	NA	NA	NA





16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	CO2 Fire Extinguisher provided near electric meter	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.
 In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter no. F.6/DFS/MS/2021/SZ/531 dated 26/07/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note:- Pota cabins are also seen in the school premises. If agreed FSC may be issued to only one block without pota cabins.


 Signature of the Inspecting Officer
 Name Uday V/S Singh
 Designation ADO/DWR


 11/6/24

CFO(S2) 
 12/6/2024
 Director 
 17/2/24

